

# ATTESTATION OF CONFORMITY

Issued to: LUMINAID B.V.  
Belder 45  
4704 RK Roosendaal  
The Netherlands

For the product: Line light system with LED light source

Trade name: LUMINAID

Models: DataLux.IQ Line Lighting and DataLux.LT Line Lighting  
Types: LUM-DL3EIQ-xxxx-xxxx, LUM-DL2EIQ-xxxx-xxxx  
LUM-DL1EIQ-xxxx-xxxx and LUM-DL30IQ-xxxx-xxxx

LUM-DL3ELT-xxxx-xxxx, LUM-DL2ELT-xxxx-xxxx  
LUM-DL1ELT-xxxx-xxxx and LUM-DL30LT-xxxx-xxxx

Ratings: 230 Vac, 50 Hz (mains supply voltage), 55 Vdc (operating voltage luminaires),  
5,2 – 53,3 W, max length of luminaire is 3 m, Class II, IP65, ta = 40 °C

Manufactured by: LUMINAID B.V.  
Belder 45  
4704 RK Roosendaal  
The Netherlands

Requirements: DIN VDE 0710-13:1981 – Luminaires with operating voltages below 1000 V –  
Luminaire safety to ball throwing



Indication:

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 2218342.00. This attestation belongs to test report no. 2218342.60.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 21 December 2018

Number: 2218342.01-AOC

DEKRA Certification B.V.

A.C. Slingerland  
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed